

SOMERS FIRE & RESCUE

Fire Inspector
Capt Joe Scruggs

P.O. Box 197
Somers, WI 53171
(262)-620-3285
jscruggs@somers.org



VILLAGE OF SOMERS HYDRANT COLOR QUICK-SHEET

All hydrants shall be Mueller Super Centurion A-423 with two 2-1/2" NST nozzle outlets and one factory installed 5" Storz connection and cap.

The entire hydrant shall be painted except the Storz connection.

The hydrant shall be one of the following three colors;



RED

Hydrants that are non-pressurized or referred to as at "city" pressure and are in the right of way, managed by the municipality.

Existing hydrants to re-paint using Mueller Red (Sherwin-Williams KEM400 F75RH1). New factory Hydrants using Mueller Red (Sherwin-Williams Polane F63YL15).

BLUE

Hydrants that are on private property and are non-pressurized or referred to as at "city" pressure. These are maintained by the property or tenant owner.

Existing hydrants to re-paint using Mueller Blue (Sherman Williams Blue Chip SW6959). New factory Hydrants using Mueller Blue (Sherwin-Williams Polane F63RXL9667).

YELLOW

Hydrants that are pressurized, typically behind a fire pump on a fire loop. These are maintained by the property or tenant owner.

Existing hydrants to re-paint using Mueller Yellow (Sherwin-Williams KEM400 F75YH1). New factory Hydrants using Mueller Yellow (Sherwin-Williams Polane F63YL14).

For Village standard detail specifications on hydrants see:
Somers Water Utility & Somers Fire Ch 16 at somers.org